

Government Street Wharf Replacement

KITTERY, MAINE

Addendum 8

Additional Information:

At a minimum, the following Sediment and Erosion Control Measures are to be followed during construction of the new wharf and pier (from Section 4 Replacement of Structures of the Maine DEP Permit by Rule Standards), Section C:

Item 10. Wheeled or tracked equipment may not be operated in the water.

Item 12. All debris or excavated material must be stockpiled either outside the protected resource or hauled off site unless it is to be used as backfill in which case it will be stored in a manner to prevent erosion off the stockpile from entering the resource. The exceptions to this requirement are storing of crushed or excavated rock fragments that are considered relatively clean and not prone to sedimentation. Exposed soil or gravel shall be permanently covered as soon as practicable or otherwise covered with geotextiles to prevent erosion. Any signs of sedimentation or erosion of exposed soils or gravel are enough to require the immediate covering with geotextile fabrics.

Item 13. Uncured concrete may not be placed directly into the water. If concrete is cast-in-place, it will be protected by coffer dams and allowed to cure in the forms for a 7-day period before forms are removed. No washing of tools, forms or concrete handling equipment may occur adjacent to the project site. No dumping of excess, unused concrete is allowed anywhere on the site. If pre-cast concrete is used it shall be cured for no less than 3 weeks prior to installation.

Item 14. The use of pressure-treated wood is allowed if it has been air-dried for a period of 21 days prior to construction. Wood treated with creosote or pentachlorophenol is not allowed. Existing creosote treated piles shall be disposed of off-site upon removal.